


1. HYDRANT LEADS SHALL BE INSTALLED WITH CLASS B BEDDING.
2. HYDRANT LEAD TRENCH SHALL BE BACKFILLED WITH GRANULAR MATERIAL.
3. ALL CONNECTIONS ON HYDRANT LEAD SHALL BE RESTRAINED MECHANICAL JOINTS WITH MEGA LUG.
4. ALL HYDRANT TO HAVE A 5-1/4 IN PUMPER NOZZLE AND TWO 2-1/2 IN HOSE NOZZLES
5. ALL HYDRANTS ASSEMBLY'S SHALL BE "LIVE TAPPED" TO THE EXISTING WATER MAIN..



# PVC HYDRANT BRANCH DETAIL

N.T.S.